

- 2. Materials and construction to be in accordance with current B.S. 1722: part 7.
- 3. All timber and pressure treatment to be in accordance with the specification.
- 4. When specified, painting to be in accordance with the specification.
- 6 Augered posts set in 300 dia. hole should be backfilled with suitable excavated material being well compacted as filling proceeds. If excavated material is unacceptable for backfilling post holes shall, at the direction of the Project Manager, be backfilled to at least half their depth with Concrete Class GEN2.
- 9. Netting secured to posts by each horizontal wire with 1 No. 40x8 S.W.G. galvanised staple



COUNTY HALL Peas Lane Hertford, Herts **SG13 8DN**

Phone: 01992 555555

Revisions

AUG 23 A -UPDATED DETAIL

- В-
- C -

Drawing Title

NAILED WOODEN POST AND FOUR RAIL FENCE TYPE MPR & SPR

Dwg No: HST/0300/010

Scale at A4: NTS

Drawn	Approved	Revised
RD	JE	
Checked	Date	Date
STM	JULY '11	