



NOTES

1. All dimensions are in millimetres.
2. The minimum depth from the top of grating to the top of gully outlet is to be 750mm when the connecting pipe is under the carriageway and 600mm elsewhere.
3. Gully pots are to be of precast concrete to BS 5911: Part 2. Gully pots shall be trapped and provided with a hot dip galvanised stopper and chain with bayonet type fixing
4. All kerb entry gullies shall be provided with a road bar.



COUNTY HALL
 Pegs Lane
 Hertford, Herts
 SG13 8DN
 Phone: 01992 555555

Revisions

- | | | |
|-----|--------|----------------|
| A - | AUG 23 | UPDATED DETAIL |
| B - | | |
| C - | | |

Drawing Title

TYPICAL KERB
 INLET GULLY

Dwg No: HST/0500/009

Scale at A4 : N.T.S.

Drawn	Approved	Revised
PAS	JE	
Checked	Date	Date
STM	08/11	