



NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS STATED OTHERWISE.
2. SHOULD THE CONTRACTOR WISH TO LAY EDGINGS ON MORTAR BED THE FOUNDATION SHALL BE LAID TO ALLOW FOR A 12mm THICK DESIGNATION (I) MORTAR BED.
3. BACKING CONCRETE SHALL BE CONTINUOUS. FRONTING CONCRETE SHALL BE SUFFICIENT TO SUPPORT THE EDGINGS AT THE ENDS AND JOINTS DURING CONSTRUCTION OF ADJACENT FOOTWAY OR PAVED AREA.
4. ORIENTATION OF EDGING SECTIONS TO TYPE EBN SHALL BE AS DESCRIBED IN THE WORK ORDER FOR EACH APPLICATION.
5. EDGINGS SHALL BE MANUFACTURED BY WET PRESS PROCESS AND SHALL COMPLY WITH BS EN 1340.



COUNTY HALL
 Pegs Lane
 Hertford, Herts
 SG13 8DN
 Phone: 01992 555555

Revisions

- | | | |
|-----|--------|----------------|
| A - | FEB 20 | REVISED DETAIL |
| B - | AUG 23 | UPDATED DETAIL |
| C - | | |

Drawing Title

PRECAST CONCRETE EDGING
 FOOTWAY AND PAVED ARE APPLICATION

Dwg No: HST/1100/019

Scale at A4 : 1:10

Drawn	Approved	Revised
YS	HH	A
Checked	Date	Date
KK	JULY 11	FEB 20