



NOTES:

1. Box shall be IP65, polycarbonate with clear cover not less than 280mm x 190mm x 130mm (as RS506-069) or similar. the box shall be supplied by the contractor complete with 1 spare gland plate (RS 506-104)
2. Rotary isolator (switch disconnecter) shall:- be IP65 in a polycarbonate enclosure; be padlockable; have all a C22B rating (25A Pedestrian Crossing Fuse) (60A Junction Fuse) be suitable for connection at the 'origin'; have Ik not less than 16kA; shall be supplied by the contractor.
3. All cables in and out of the isolator and the telecoms box shall pass through compression glands that maintain the equipment IP rating.
4. Earth bonding shall comply with section 543 of BS 7671 (IEE wiring regulations)
5. Refer to Appendix 14/4 and DRG.NO. HST/1400/029 for earth rod requirements.



COUNTY HALL  
 Pegs Lane  
 Hertford, Herts  
 SG13 8DN  
 Phone: 01992 555555

Revisions

- A -
- B -
- C -

Drawing Title

TRAFFIC SIGNALS SERVICE  
 PILLAR GENERAL LAYOUT

Dwg No: HST/1200/504

Scale at A4 : N.T.S.

Drawn	Approved	Revised
GW	CJG	-
Checked	Date	Date
AJM	JULY '11	-