



NOTES:

1. Box shall be IP65 Polycarbonate with clear cover, (RS498-5107 or similar) large enough to fit standard BT master socket. Fitted with 2 off glands. (1x to fit cable 5-10mm 1x to fit standard BT telephone extension lead).
2. 4 way Lockable Consumer Unit (metal case) MK, SCAME or similar. Fitted with 2x32A, 2x20A breakers and 1x lockable Isolator/Main ON/OFF switch.
3. All cables in and out of the Consumer Unit and the Telecoms box should pass through compression glands that maintain the equipment IP rating.
4. Earth Bonding shall comply with section 543 of BS7671 (IEE wiring regulations).
5. Refer to Appendix 14/4 and Drg No HST/1400/039 for Earth Rod requirements.



COUNTY HALL
 Pegs Lane
 Hertford, Herts
 SG13 8DN
 Phone: 01992 555555

Revisions

- A -
- B -
- C -

Drawing Title

ITS SERVICE PILLAR
 GENERAL LAYOUT

Dwg No: HST/1200/511

Scale at A4 : N.T.S.

Drawn	Approved	Revised
PT	CJG	-
Checked	Date	Date
AJM	JULY '11	-