



NOTES:

1. Unless in footway pillar shall be provided with a 900mm x 600mm x 50mm concrete paving flags in front of door.
2. Have a thin coating of graphite grease applied to all moving parts (hinges and locks etc).
3. Labels in accordance with the Specification (HST-1400-003).
4. The gap between the inside of the pillar cap and the column base shall be no greater than 3mm.
5. The pillar cap shall be fixed according to the manufacturers specification.
6. The gap between the pillar cap and the column base, and the heads of the screws shall be filled with sealant.
7. The pillar cap shall be sized to suit the column base.
8. Earth electrode mat as per drawing HST-1400-039.

LABELS:

1. "Street Lighting" - 50mm high black text on white background.
2. Electrical hazard sign with 230 volt sub plate as per drawing HST-1400-003 label A and !.
3. Maintenance number as per HST-1300-008.

Notes						IWP No.				Drg No. HST-1400-024			Rev. A														
						<table border="1"> <tr> <td></td> <td>CAD</td> <td>Drawn</td> <td>Checked</td> <td>Approved</td> </tr> <tr> <td>Initials</td> <td>PB</td> <td>PB</td> <td>ADS</td> <td>PW</td> </tr> <tr> <td>Date</td> <td>01/10</td> <td>04/10</td> <td>04/10</td> <td>04/10</td> </tr> </table>					CAD	Drawn	Checked	Approved	Initials	PB	PB	ADS	PW	Date	01/10	04/10	04/10	04/10	Project Title HCC STANDARD DETAIL DRAWINGS		
		CAD	Drawn	Checked	Approved																						
	Initials	PB	PB	ADS	PW																						
Date	01/10	04/10	04/10	04/10																							
					Sht. No. 1 OF 1				Drawing Title STUB PILLAR																		
					Scales NTS																						
A		Various drawing revisions			AS	RC	DOK	07/21																			
		Description			Dwn	Chk	App	Date																			

