



DETAIL OF CABLE PIT AND DUCT

NOTES:

1. All dimensions are in millimetres.
2. All ducts shall be 100mm dia thick walled rigid medium density polyethylene smooth bore.
3. Ducts shall be permanently coloured according to their use as below:
 Orange = Private power cables (Signals, Street Lighting)
 Black = Distribution Network Operator (DNO)
 Grey = BT
4. All ducts shall be left with a spare draw wire in them after any cables are pulled.
5. All ducts shall protrude by at least 75mm in to the pit/pillar to allow for identification.
6. Selected Granular fill type 6N

Notes

A	Various drawing revisions	AS	RC	DOK	07/21
	Description	Dwn	Chk	App	Date

IWP No.				
	CAD	Drawn	Checked	Approved
Initials	PB	PB	ADS	PW
Date	01/10	04/10	04/10	04/10
Sht No.	1 OF 1			
Scales	NTS			

Drg. No.	HST-1400-038	Rev.	A
Project Title	HCC STANDARD DETAIL DRAWINGS		
Drawing Title	DUCT AND PIT DETAILS PLAN 2		



COUNTY HALL
 Pegs Lane
 Hertford, Herts
 SG13 8DN
 Phone: 01992 555555